

2021 JUN 28 AM 9:13



MISSISSIPPI STATE DEPARTMENT OF HEALTH

2020 CERTIFICATION

Consumer Confidence Report (CCR)

Beat III Greene County Water System
Public Water System/Name

210001
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

CCR DISTRIBUTION (Check all boxes that apply.)

INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bills (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other _____	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U. S. Postal Mail	
<input type="checkbox"/> Distributed via E-Mail as a URL (Provide Direct URL): _____	
<input type="checkbox"/> Distributed via E-Mail as an attachment	
<input type="checkbox"/> Distributed via E-Mail as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations)	
<input checked="" type="checkbox"/> Posted online at the following address (Provide Direct URL): <u>https://ccrwater.net/beat3water-</u>	<u>6/1/21</u>

CERTIFICATION

92289

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Peggy Moore
Name

Manager
Title

6/24/2021
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800

(NOT PREFERRED)

CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021

2021 MAY 13 AM 8:10

PWS ID#: 0210001			TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
Inorganic Contaminants									
8. Arsenic	N	2020	1	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	
10. Barium	N	2020	.0665	.0204 - .0665	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
14. Copper	N	2018/20	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
17. Lead	N	2018/20	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
Sodium	N	2019*	3400	2200 - 3400	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.	
Volatile Organic Contaminants									
76. Xylenes	N	2020	.000568	.000563 - .000568	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories	
Disinfection By-Products									

Chlorine	N	2020	1.2	.70 – 1.68	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	------------	------	---	----------	-----------------------------------------

** Most recent sample. No sample required for 2020.*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Beat III Greene County Water System, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

ACCOUNT NO.	SERVICE FROM	SERVICE TO	RETURN THIS STUB WITH PAYMENT TO:		PRESORTED FIRST-CLASS MAIL U.S. POSTAGE PAID PERMIT NO. 15 RICHTON, MS
080812400	04/15	05/15	BEAT 3 GREENE COUNTY WATER SYSTEM 39660 HWY. 63 NORTH RICHTON, MS 39476 www.beat3gcwater.com		
SERVICE ADDRESS					
705 POPE ROAD					
METER READING					
CURRENT	PREVIOUS	USED			
322	321	1			
CHARGE FOR SERVICE					
PAY NET AMOUNT ON RECEIPT OF BILL		BILL DATE	PAY GROSS AMOUNT AFTER THE 15TH		
61.22		06/10/2021	63.68		
NET AMOUNT		SAVE THIS	GROSS AMOUNT		
61.22		2.46	63.68		

CCR <https://ccrwater.net/beat3gcwater-92289>

RETURN SERVICE REQUESTED

WTR 23.00
 BT3 1.00
 INS 5.00
 TAX 1.61
 PAST DUE 30.61
 NET DUE >>> 61.22
 SAVE THIS >> 2.46
 GROSS DUE >> 63.68

080812400
 DESTIN PIPELINE, LLC
 C/O PROKARMA
 POST OFFICE BOX 2410
 OMAHA, NE 68103-2410